

LOCATION

103 W. HARRISON Ave

CITY

GAST.

BETWEEN

N. Marietta St.

STREET &

Logan St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	37'			9-12-96
MAIN TO PROP. LINE	"	"	4'			
PROP. LINE TO BLDG.	"	"	33'			

ENTERS:

Same

BRANCHED INTO:

TAP SIZE:

3/4"

PRESSURE

60

PSI

INCHES W.C.

LOCATION

95' West from (C) of N
Marietta St.

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

M

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

96

DEPTH:

3 FT. 0

IN.

LOCATION

South Side of W. Harrison Ave.

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY