

LOCATION 115 Harrison Dr. CITY GASTONIA

BETWEEN S. New Hope Rd. STREET & Crest Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>88'</u>	<u>2-19-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>58'</u>			

ENTERS: 115 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 375' NE' of center of

S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huff-Litt

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 14' SE of center of Harrison Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 26733

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY