

LOCATION 116 W HARRISON AVE Apt R CITY CRASTONIA
BETWEEN LOGAN ST. STREET & N. FALLS ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>44'</u>			<u>9-10-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>44'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 61' West from @
of Logan St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AP
MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96
DEPTH: 1 FT. 6 IN. LOCATION East Side of 116 W. HARRISON ST.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		