

LOCATION 118 HarrisonCITY GASTONIA

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:

PRESSURE

P.S.I.


INCHES W.C.

LOCATION

PRESSURE TEST: @ _____ psi For _____ Hrs. By _____

MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: _____ Ft. _____ In. LOCATION _____

"A" P/S READING 1.0 TOTAL ANODES 1* 1 17* _____ L.R. # _____REMARKS: Install 1 lb Anode to I/S

Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	