

LOCATION 122 HARRISON DR CITY GASTON, S
BETWEEN S. NEW HOPE STREET & Cedar St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>180'</u>	<u>7-22-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>140'</u>			

ENTERS: 122 BRANCHED INTO: ✓

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 12' E. of cop
HARRISON


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY