

LOCATION 204 W. HARRISON AVE. CITY CAS.

BETWEEN Alley STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60'</u>			<u>12-11-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>40'</u>			

ENTERS: Sam BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 12' from @ of Alley


PRESSURE TEST: @ 100 PSI FOR 14 HRS. BY mf

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION Southside of W. Harrison Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY