

LOCATION 209 W. HARRISON AVE CITY Gast.

BETWEEN N. York St. STREET & Alley STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>82'</u>			<u>12-11-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>3</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>79'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 34' from @ Alley


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY my

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION SouthSide of W. HARRISON AVE.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		