

LOCATION 212 ÷ 214 W. HARRISON AVE CITY CASST.  
 BETWEEN N. YORK ST. STREET & DEAD END STREET  


	SIZE	TYPE	LENGTH <u>212</u>	INSTALLED <u>214</u>	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>109'</u>	<u>21'</u>		<u>12-12-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>21'</u>	<u>6'</u>		
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>88'</u>	<u>15'</u>		

 ENTERS: 214 W. HARRISON AVE BRANCHED INTO: 214 W. HARRISON AVE  
 TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 274' from @ of N. YORK ST.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MP  
 MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
 DEPTH: 3 FT. 0 IN. LOCATION Southside of W. HARRISON AVE

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		