

LOCATION 220 W. HARRISON AVE CITY CAS.  
BETWEEN N. YORK ST. STREET & DEAD END STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>104'</u>			<u>12-12-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>84'</u>			

ENTERS: SAM 4 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 84' FROM @ of N. YORK ST.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MY  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96  
DEPTH: 3 FT. 0 IN. LOCATION SOUTH SIDE OF W. HARRISON AVE

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY