

LOCATION 311 & (401) W. HARRISON AVE CITY CAS.

BETWEEN N. York St. STREET & Hwy 321 STREET

	SIZE	TYPE	LENGTH <u>311</u>	<u>401</u> INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>82'</u>	<u>27'</u>		<u>12-16-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>11</u>	<u>26'</u>	<u>4'</u>		
PROP. LINE TO BLDG.	<u>1"</u>	<u>11</u>	<u>60'</u>	<u>23'</u>		

ENTERS: 401 W. HARRISON AVE BRANCHED INTO: 311 W. HARRISON AVE

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 268' from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ML

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION NORTH SIDE of W. HARRISON AVE

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>		

