

LOCATION 1508 Hantgrove Ave CITY GASTON, N.C.
BETWEEN Cloverdale Ave STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>378'</u>	<u>5-16-02</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>353'</u>			

ENTERS 1508 BRANCHED INTO
TAP SIZE 42 PRESSURE 60 PSI INCHES W.C. LOCATION 138' S. of center of Cloverdale Ave

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.K.
MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1966
DEPTH 3 FT 0 IN LOCATION 8' E. of center of Hantgrove Ave

"A" P/S READING TOTAL ANODES 1# 0 17# 0 LR # 110490

REMARKS

