

LOCATION 2467 Hawk's Ridge Dr. CITY GASTON

BETWEEN Red TAIL CT STREET & PERAGINE CT. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>64'</u>	<u>3-31-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>59'</u>			

ENTERS: 2467 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 28' N. of center of Red TAIL CT


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY 3-1

MAIN SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION 21' W. of center of Hawk's Ridge Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 233186

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	