

LOCATION 505 & 507 Hawthorne Lane Split Services CITY GASTONIA
 BETWEEN Fairfield Dr. STREET & Fair Field Dr. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|----------------------------------|---------------|
| MAIN TO BLDG. | 3/4 | P | 3' | 6-4-94 | Tied over 103' | 505 - 2-10-84 |
| MAIN TO PROP. LINE | | | | | Existing 3/4" P. 507 | 507-6-25-87 |
| PROP. LINE TO BLDG. | | | | | Tied over 16' Exist. Plastic 505 | |

ENTERS: 505 Hawthorne Lane BRANCHED INTO: 507 Hawthorne Lane
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 352' S of C of Fairfield Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
 MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993
 DEPTH: 3 Ft. 0 In. LOCATION 16' E of C of Hawthorne Lane

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. #

REMARKS: Tied over Existing 3/4" Plastic Service to New 2" Plexco Plastic Gas Main
505 & 507 Hawthorne Lane, Split Services.

~~Gas Main Replacement~~

~~Program~~



| Test Station | | |
|--|------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | Risers Plastic |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY

on 505 & 507