

LOCATION 1746 1/2 Haynes St CITY Gastonia

BETWEEN Bessemer City Rd STREET & Webb St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	97'	1-31-97		
MAIN TO PROP. LINE	1"	"	-0-			
PROP. LINE TO BLDG.	1"	"	97			

ENTERS: 1746 BRANCHED INTO: 1/2

TAP SIZE: 3/4 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 55' N. of Cob

HAYNES


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 1 FT. 4 IN. LOCATION

"A" P/S READING 1 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	RR	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY