

LOCATION 1819 Haynes Ave CITY Castañia

BETWEEN Bessemer City Rd STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>Plastic</u> | <u>52'</u> | <u>11/4/96</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | | <u>42'</u> | | | |

ENTERS: 1819 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION West side of 1819

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL — PLASTIC _____ YEAR INSTALLED 1961

DEPTH: 2 FT. 6 IN. LOCATION South side of Haynes Ave

"A" P/S READING 1.20 TOTAL ANODES 1# 0 17# 0 L.R. # 625725

REMARKS:

| Test Station | | | ENG. DEPT. USE ONLY |
|--|----------|-------|---------------------|
| Reading & Location | Lead | Volts | |
| P/S Pipeline Lead - Red New Service | S | | |
| P/S Pipeline Lead - White Existing Main | E | | |

