

LOCATION 1833 Haynes Ave CITY Gastonia

BETWEEN Bessemer City Rd STREET & Webb STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50'</u>	<u>1-7-99</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>43</u>			

ENTERS: 1833 BRANCHED INTO: -

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 16' s. of caf.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY JP Haynes Ave.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1959

DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING 1.0 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	<u>R</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	