

LOCATION 3557 Heather LnCITY GastoniaBETWEEN WRENSTREET & WREN

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>156'</u>			
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>111'</u>			

ENTERS 3557BRANCHED INTO —TAP SIZE 1/2PRESSURE — PSI

INCHES WC

LOCATION 19' S. of C ofPRESSURE TEST 100 PSIFOR 1/4" RSBY JPHeatherMAIN-SIZE 2"C.I. —BARE STEEL —COATED STEEL —PLASTIC ✓YEAR INSTALLED 1953DEPTH 3 FT0 INLOCATION —"A" P/S READING PTOTAL ANODES 1# —17# —L.R. # —

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>2R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	