

LOCATION 1312 Heatherloch DR

CITY GASTONIA

BETWEEN CAIRNSMORE PLACE

STREET &amp; DORNICH DR

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	108'	11-9-94	143' of 3/4" c/w	
MAIN TO PROP. LINE	11	11	11'			
PROP. LINE TO BLDG.	11	11	97'			

ENTERS: 1312

BRANCHED INTO: -

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 16' E. of Cap  
of Heatherloch DR

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1975


DEPTH: 3 Ft. 0 In. LOCATION 403 North of Center of Cairnsmore Pl

"A" P/S READING 1.00

TOTAL ANODES 1# — 17# —

L.R. #

REMARKS:



## Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	P
P/S Pipeline Lead - White Existing Main	E	