

LOCATION

1401 HEATHERLOCK DA

CITY

GASTONIA

BETWEEN

Cheriot LANE

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.					18' Existing 3/4	
MAIN TO PROP. LINE					GW Pipe	
PROP. LINE TO BLDG.						

ENTERS: 1401

BRANCHED INTO: 0

TAP SIZE:

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @

psi

For Hrs.

By Used Existing Pipe & Riser.

MAIN-SIZE

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

DEPTH:

Ft.

In.

LOCATION

"A" P/S READING


.90

TOTAL ANODES 1*

17*

L.R. #

REMARKS: Relocated Existing 3/4 GW Service From BACK OF House For New Addition to House to Side OF House. Used Existing Pipe & Riser. See Drawing on Reverse Side. Bonded Dresser.



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser .90
P/S Pipeline Lead - White Existing Main	E	