

LOCATION 1531 Heatherloch Dr. CITY BASTONIA

BETWEEN Grampian Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	90'	3-2-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	85'			

ENTERS: 1531 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 40 P.S.I. INCHES W.C. LOCATION 126' N. of center of


PRESSURE TEST: @ 100 psi For 1/2 Hrs. By S. Huffstutz

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1973

DEPTH: 3 Ft. 0 In. LOCATION 15' W. of center of Heatherloch Dr.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 72991

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY