

LOCATION 4229 Heatherstone Dr CITY GASTONIA
BETWEEN Union Rd STREET & Frostwood Dr STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	108'	5/28/96		
MAIN TO PROP. LINE	3/4"		38'			
PROP. LINE TO BLDG.	3/4"		20'			

ENTERS: 4229 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION W side of 4229

PRESSURE TEST: @ 180 psi For 44 Hrs. By DF
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1990
DEPTH: 2 Ft. 6 In. LOCATION South side of Heatherstone Dr

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 272 617

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY