

LOCATION 634 Heathwood CITY Gastonia  
 BETWEEN Myrtle woods STREET & W. Fifth Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>22</u>	<u>5-19-99</u>		
MAIN TO PROP. LINE	<u>1 1/2</u>	<u>1 1/2</u>	<u>0</u>			
PROP. LINE TO BLDG	<u>1 1/2</u>	<u>1 1/2</u>	<u>22</u>			

ENTERS: 634 BRANCHED INTO 0  
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES WC LOCATION 70' S of C of Myrtle woods


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY BC

MAIN-SIZE 3/4 C I      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 2 FT IN LOCATION 53' E of C of Heathwood

\*A\* P/S READING Plastic TOTAL ANODES 1# - 17# - LR # -

REMARKS  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	