

LOCATION 2000 Helen st. CITY East.
BETWEEN Pamela sl. STREET & Audrey STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>140'</u>			<u>6-26-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>128</u>			

ENTERS: SAM BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 299' From @ of Pamela

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 0 IN. LOCATION South of HELEN S

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY