

LOCATION 2035 Helen Dr CITY Gast.  
BETWEEN Audrey Dr. STREET & Pamela Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>?</u>	<u>67'</u>		<u>6</u>	<u>27-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>62'</u>			


ENTERS: Same BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W.C. LOCATION 280' from C of  
Audrey

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DHF  
MAIN-SIZE 3/4" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION South side of Helen Dr.

"A" P/S READING ? TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY