

LOCATION 1902 & 1904 Hemlock St CITY CASPER
BETWEEN Grover STREET & Ida STREET


	SIZE	TYPE	1902 LENGTH	1904	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>166'</u>	<u>48'</u>		<u>1902 Hemlock St.</u> <u>54' of 3/4" CPW</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>2'</u>		<u>3.22-95</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>61'</u>	<u>46'</u>		<u>1904 Hemlock St.</u> <u>54' of 3/4" CPW</u>	

ENTERS: 1902 BRANCHED INTO: 1904
TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP
MAIN-SIZE 1 1/2 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1955
DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING .6 TOTAL ANODES 1# 1 17# 1 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>0.62</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY