

LOCATION 707 Henry StCITY GastoniaBETWEEN MAJOR

STREET &amp;

Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>12'</u>			<u>5-25-94</u>
MAIN TO PROP. LINE					<u>12' of 3/4" BARE</u>	
PROP. LINE TO BLDG.						

ENTERS: 707

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.


LOCATION

PRESSURE TEST: @ 100 psiFor 1/4 Hrs.By JPMAIN - SIZE 3/4C.I.   BARE STEEL   COATED STEEL   PLASTIC   YEAR INSTALLED 1956DEPTH: 1 Ft. 6 In.

LOCATION

"A" P/S READING 160TOTAL ANODES 1\* 1 17\*   L.R. #   

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P.</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY