

LOCATION 710 Henry Ave. CITY East  
BETWEEN Prayn STREET & Dead End STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>36'</u>		<u>4-11</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>16'</u>			

ENTERS: 710 Henry BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION E. side of 710

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By G/K  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION S. Side of Henry Ave.

"A" P/S READING P TOTAL ANODES I# \_\_\_\_\_ I7# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>7</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY