

LOCATION 714 HENRY AVE CITY GAST.

BETWEEN Prior STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>28'</u>		<u>4-11-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>18'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>10'</u>			

ENTERS: 714 Henry Ave. BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION E. Side of 714


PRESSURE TEST: @ 106 psi For 1/4 Hrs. By AK

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 96

DEPTH: 3 Ft. In. LOCATION S. of Henry Ave.

"A" P/S READING: P TOTAL ANODES 1* 17* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY