

LOCATION 2949 Heritage Commons CITY Crastonia
BETWEEN Kennett Ave. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>4-24-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>55'</u>	<u>"</u>		

ENTERS 2949 BRANCHED INTO 0
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 544' north

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody of center of Kennett Ave.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 43' west of center of Heritage Commons

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00268394

REMARKS New 3/4" plastic service

