

LOCATION 2978 Heritage Commons Ln. CITY GASTONIA
BETWEEN Kennett Ave STREET & Cut-de-Str STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>88'</u>	<u>7-27-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>53'</u>			

ENTERS 2978 BRANCHED INTO

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 84' N. of center of Kennett Ave

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SIL

PIPE SIZE 3/4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 2 FT 0 IN LOCATION 18' E. of center of Heritage Commons Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 656911

REMARKS

