

LOCATION 305 Hickory Hollow Rd. CITY Gaston, N.C.  
BETWEEN Creek Ridge Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>7-23-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>75'</u>			

ENTERS 305 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 264' S. of center of Creek Ridge Rd.


PRESSURE TEST @ 160 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 55' W of center of Hickory Hollow Rd.

"A" P/S READING 2 TOTAL ANODES 1# 17# LR # 586057

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	