

LOCATION 212 & 214 N. Highland St. CITY GAST.
BETWEEN AIRLINE STREET & RANKIN STREET

	SIZE	TYPE	212 LENGTH	214	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	73'	33'		5-8	96
MAIN TO PROP. LINE	"	"	40'	0			
PROP. LINE TO BLDG.	"	"	33'	33'			

ENTERS: 212 BRANCHED INTO: 214

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. of 212
W. of 214


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GV

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 96

DEPTH: 3 FT. _____ IN. LOCATION W. of N. Highland

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY