

LOCATION 312 N. Highland St CITY GAST.  
BETWEEN WALNUT STREET & RANKIN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>100</u>		<u>5.10</u>	<u>96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>60</u>			

ENTERS: 312 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION N. side of 312

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GR  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 FT. \_\_\_\_\_ IN. LOCATION W. side of N. Highland

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY