

LOCATION 324 N. Highland St. CITY East.
BETWEEN MAUNEY STREET & WALNUT STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>153'</u>		<u>5. 10</u>	<u>'96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>113'</u>			

ENTERS: 324 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. Side of 324

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GL
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 96
DEPTH: 3 FT. _____ IN. LOCATION W- Side of N. Highland

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>7</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		