

LOCATION 603 N. Highland St. CITY Princeton  
BETWEEN Murray Ave. STREET & W. Davidson St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>188'</u>	<u>10-3-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>178'</u>	<u>"</u>		

ENTERS 603 BRANCHED INTO P  
TAP SIZE 1/2" PRESSURE 40 PSI \_\_\_\_\_ INCHES W C LOCATION 575' North-


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R. Woody at center of Murray Ave.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH 3' FT 0" IN LOCATION 22' west of center of N. Highland St.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 081512

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.5v</u>