

LOCATION 615 N. Highland St.CITY ChattanoogaBETWEEN W. DavidsonSTREET & W. Main

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>		<u>56' of 1 1/4" BARE</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>		<u>5-6-54</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>51'</u>			

ENTERS: 615BRANCHED INTO: 0TAP SIZE: 3/8

PRESSURE

20

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi

For

44 Hrs.

By

EPMAIN-SIZE 2"C.I. BARE STEEL ☒COATED STEEL PLASTIC YEAR INSTALLED 1937

DEPTH:

1

Ft.

6


In.

LOCATION

"A" P/S READING

.5TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.195 V</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY