

LOCATION 905 N. Highland St CITY GASTONIA  
BETWEEN Davidson STREET & Normant STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>35'</u>	<u>2-13-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>25'</u>			


ENTERS: 911 N. Highland St. BRANCHED INTO: 905 N. Highland St.  
TAP SIZE: 3/4 Straight Plastic Tee PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 217' W of Caf Davidson St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
Service MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 11-21-95

DEPTH: 3 FT. 0 IN. LOCATION 77' W of Caf N. Highland St.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 080641

REMARKS: Split Service

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>	