

LOCATION 911 N. HighlandCITY GASTONIABETWEEN W DavidsonSTREET & DEAD END

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	346'	11-21-95		
MAIN TO PROP. LINE	3/4	P	33'			
PROP. LINE TO BLDG.	3/4	P	313'			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 198 N OF W. DavidsonPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL X COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED P-30DEPTH: 3 Ft. 0 In. LOCATION S' EAST OF N. Highland"A" P/S READING .8 TOTAL ANODES 1\* \_\_\_\_\_ 17\* 1 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-RISER
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY