

LOCATION 410 S. HIGHLAND ST CITY GASTONIA  
BETWEEN FOURTH AVE STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>73'</u>	<u>6-16-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>plastic</u>	<u>31'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>plastic</u>	<u>42'</u>			

ENTERS 410 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI          INCHES W C LOCATION 289' S of C of  
FOURTH AVE


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R.R

MAIN-SIZE 2" C I          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 2000

DEPTH: 3' FT 0 IN LOCATION 14' W OF C of S. HIGHLAND ST

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # 00461799

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>