

LOCATION 3013 High Ridge Ct CITY GASTONIA
BETWEEN HOFFMAN RD STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	D	96'	01-04-01		
MAIN TO PROP LINE	3/4	D	5'			
PROP LINE TO BLDG	3/4	D	91'			

ENTERS - BRANCHED INTO -
TAP SIZE PRESSURE _____ PSI _____ INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY EP

MAIN-SIZE 2 1/2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH 2 FT 6 IN LOCATION

"A" P/S READING SP TOTAL ANODES 1# 17 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	