


LOCATION	3045 High Ridge Ct.		CITY	Gastonia		
BETWEEN	Hoffman Rd.		STREET &	STREET		
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	8 1/4"	P	79'	7-26-00		
MAIN TO PROP LINE	3 1/4'	P	5'			
PROP LINE TO BLDG	3 1/4"	P	74'			
ENTERS	3045		BRANCHED INTO			
TAP SIZE	3 1/4"	PRESSURE	60 PSI	INCHES WC	LOCATION 510' E. of center of Hoffman Rd.	
PRESSURE TEST @	100 PSI	FOR	44 HRS	BY	S.H.	
MAIN-SIZE	2"	C I	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED 1998
DEPTH	3 FT	0 IN	LOCATION 37' S. of center of High Ridge Ct.			
"A" P/S READING	P		TOTAL ANODES 1#	0	17#	0
REMARKS	LR # 642304					



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	