

LOCATION 605 & 609 Hillcrest Ave CITY Gastonia
BETWEEN Florida STREET & Lineberger St STREET

	SIZE	TYPE	605 LENGTH 609		INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	3/4	Plastic	93'	30'			1-24-98
MAIN TO PROP. LINE	"	"	19'	3'			
PROP. LINE TO BLDG.	"	"	74'	27'			

ENTERS: 605 BRANCHED INTO: 609

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING Plastic TOTAL ANODES 1# 17 # _____ L.R. # ☒

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Rise</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY