

LOCATION 614 Hillcrest Ave CITY GASTONIA
BETWEEN Florida STREET & Lineberger STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>111'</u>			<u>1-24-98</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>54'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>57'</u>			

ENTERS: 614 BRANCHED INTO: -

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY