

LOCATION 826 Hill Crest Ave. CITY GASTONIA
BETWEEN Athenian Dr. STREET & Home Trail STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>38'</u>	<u>9-26-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>16'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>22'</u>			

ENTERS: 834 Hill Crest Ave. BRANCHED INTO: 826 Hill Crest Ave.
TAP SIZE: 3/4 Straight Plastic Tee PRESSURE 60 P.S.I. INCHES W.C. LOCATION 360' W of C of Home Trail


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

Service MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1990 ^{Renewed}

DEPTH: 2 Ft. 0 In. LOCATION 124' N of C of Hill Crest Ave.

"A" P/S READING Plastic N/A TOTAL ANODES 1* 17 * L.R. # 485380

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY