

LOCATION 1909 Hillgate Ave. CITY CASTAVERIA

BETWEEN Robinwood Rd STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>7-19-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>57'</u>			

ENTERS: 1909 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 941' W. of center of Robinwood Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huff & Roth

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1969

DEPTH: 3 FT. 0 IN. LOCATION 14' S. of center of Hillgate Ave.

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 I.R. # 390159

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY