

LOCATION 1812 Hilltop C.R. CITY CASSTONIA

BETWEEN Hunt Ave. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>78'</u>	<u>5-4-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>			

ENTERS: 1812 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 135' W. of center of Hunt Ave.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBLER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1987

DEPTH: 3 Ft. 0 In. LOCATION 15' S. of center of Hilltop C.R.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 213552

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY