

LOCATION 1401 Hoffman Rd CITY Gastonia  
BETWEEN Hunters Glen STREET & Colony Woods STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>	<u>2-18-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>48'</u>			


ENTERS: 1401 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 400' E of c of  
Hunters Glen

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. IN. LOCATION 615' S of c of Hoffman Rd

"A" P/S READING plastic TOTAL ANODES 1# - 17# - L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY