

LOCATION 1562 Hoffman Rd. CITY GASTONIA
BETWEEN Pine Creek STREET & Saddle Horse STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>79'</u>	<u>3-27-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>39'</u>			


ENTERS: 1571 BRANCHED INTO: 1562
TAP SIZE: 3/4 Straight PRESSURE 60 PSI _____ INCHES W.C. LOCATION 407' w of C of Saddle Horse Ln.
P. Tee

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
Service SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 2 FT. 0 IN. LOCATION 151' S of C of Hoffman Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 172307

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY