

LOCATION 1592 Hoffman Rd

CITY GASTONIA

BETWEEN SADDLE HORSE DR

STREET & IVE CREEK

STREET

	SIZE	TYPE	LENGTH	INSTALLED	Relocated 7-13-94	RENEWED
MAIN TO BLDG.	3/4	P	97'			
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1592

BRANCHED INTO: -

TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 247' w of c of

Hoffman Rd


PRESSURE TEST: @ 100 psi For 4 Hrs. By TP

MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING 60 TOTAL ANODES 1# 1 17# L.R. #

REMARKS: .90 after anode installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	P.
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY