

LOCATION 1646 Hopman Rd. CITY Gretna  
BETWEEN Old well Ln. STREET & Saddle Horse STREET

	SIZE	TYPE	LENGTH	<del>INSTALLED</del> <u>Relocated</u>	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>9w</u>	<u>6'</u>	<u>12-7-84</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1646 BRANCHED INTO: 6

TAP SIZE: 3/4 Ser. PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 psi For 44 Hrs. By EP

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1963

DEPTH: 2 Ft. 0 In. LOCATION \_\_\_\_\_

"A" P/S READING 1.2 TOTAL ANODES 1\* 017 \* 2 L.R. # \_\_\_\_\_


REMARKS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY